

LISTING INFORMATION FOR FMRC APPROVAL GUIDE

Manufacturer:	Customer ID: 1000005082
	Project ID: 3005901
Distributor:	Class Number: 4470
	File Name: G:\ACTIVE - AG Building Materials\3005901mdt1.wpd
TYPE OF LISTING: (Check all that apply)	
<input type="checkbox"/> New (Client) <input type="checkbox"/> Completely New Listing <input checked="" type="checkbox"/> Addition to Client's listing <input type="checkbox"/> Revised (Changes part of listing) <input type="checkbox"/> Revised (Changes all of listing) <input type="checkbox"/> Name Change (Company) <input type="checkbox"/> Address Change (Approval Guide Address)	
EQUIPMENT CLASSIFICATION (Book, Chapter, Section): Building Materials, Chap. 2.F.2., Liquid Applied Roof Coverings	
COMPANY NAME (As it appears in the guide) Truco Inc	ADDRESS (As it appears in the guide) 4301 Train Ave Cleveland OH 44113

Truco Inc 4301 Train Ave Cleveland OH 44113

Roof Cover:	Eterna-Seal No. 7140FR Rubber Roof Coating
Substrate:	Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover
Application:	Brush, spray or roller applied at a min 2.0 gal/sq (0.8 L/m ²) to a max 3.0 gal/sq (1.2 L/m ²).
Hail Rating:	Class 1-SH
ASTM E 108:	Class A noncombustible at a 2 in 12 slope
Wind Rating:	Per existing roof
Roof Cover:	Eterna-Seal No. 7141FR Seam Sealer
Substrate:	Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover
Application:	Brush, spray or roller applied at a min 2.0 gal/sq (0.8 L/m ²) to a max 3.0 gal/sq (1.2 L/m ²).
Hail Rating:	Class 1-SH
ASTM E 108:	Class A noncombustible at a 2 in 12 slope
Wind Rating:	Per existing roof

Roof Cover: Eterna-Seal No. 7145FR Field Coating
 Substrate: Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover
 Application: Brush, spray or roller applied at a min 2.0 gal/sq (0.8 L/m²) to a max 3.0 gal/sq (1.2 L/m²).
 Hail Rating: Class 1-SH
 ASTM E 108: Class A noncombustible at a 2 in 12 slope
 Wind Rating: Per existing roof

ORIGINATOR Mark D. Tyrol	DATE 10/23/00	REVIEWED BY	DATE
FOR ADMINISTRATIVE USE ONLY			
L-15 RECEIVED BY		DATE	
FOR AG OFFICE USE ONLY			
DATE RECEIVED _____ CHECKED IN PS _____ CHECKED IN ACCESS _____ CHAPTER & PAGE # _____			

LISTING INFORMATION FOR FMRC APPROVAL GUIDE

Manufacturer:	Customer ID: 1000005082	
	Project ID: 3005901	
Distributor:	Class Number: 4470	
	File Name: G:\ACTIVE - AG Building Materials\3005901mdt.wpd	
TYPE OF LISTING: (Check all that apply)		
<input type="checkbox"/> New (Client) <input type="checkbox"/> Completely New Listing <input checked="" type="checkbox"/> Addition to Client's listing <input type="checkbox"/> Revised (Changes part of listing)		
<input type="checkbox"/> Revised (Changes all of listing) <input type="checkbox"/> Name Change (Company) <input type="checkbox"/> Address Change (Approval Guide Address)		
EQUIPMENT CLASSIFICATION (Book, Chapter, Section):		
Building Materials, Chap. 3., Approved Combinations...		
COMPANY NAME (As it appears in the guide)	ADDRESS (As it appears in the guide)	
Truco Inc	4301 Train Ave Cleveland OH 44113	

Truco Inc 4301 Train Ave Cleveland OH 44113

Roof Cover: Eterna-Seal No. 7140FR Rubber Roof Coating
 Substrate: Stevens Roofing Systems Div., JPS
 Elastomerics Corp. Hypalon (CSM) roof cover
 Application: Spray, roller or brush applied
 Hail Rating: SH
 ASTM E 108: Class A noncombustible at a 2 in 12 slope

Construction #1: Coating is applied over Approved Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover by spray gun, brush or roller at a min 2.0 gal/sq (0.8 L/m²) to a max 3.0 gal/sq (1.2 L/m²) rate. Meets Wind Uplift Classification per existing roof.

Roof Cover: Eterna-Seal No. 7141FR Seam Sealer
 Substrate: Stevens Roofing Systems Div., JPS
 Elastomerics Corp. Hypalon (CSM) roof cover
 Application: Spray, roller or brush applied
 Hail Rating: SH
 ASTM E 108: Class A noncombustible at a 2 in 12 slope

Construction #1: Coating is applied over Approved Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover by spray gun, brush or roller at a min 2.0 gal/sq (0.8 L/m²) to a max 3.0 gal/sq (1.2 L/m²) rate. Meets Wind Uplift Classification per existing roof.

Roof Cover: Eterna-Seal No. 7145FR Field Coating
 Substrate: Stevens Roofing Systems Div., JPS
 Elastomerics Corp. Hypalon (CSM) roof cover
 Application: Spray, roller or brush applied
 Hail Rating: SH
 ASTM E 108: Class A noncombustible at a 2 in 12 slope

Construction #1: Coating is applied over Approved Stevens Roofing Systems Div., JPS Elastomerics Corp. Hypalon (CSM) roof cover by spray gun, brush or roller at a min 2.0 gal/sq (0.8 L/m²) to a max 3.0 gal/sq (1.2 L/m²) rate. Meets Wind Uplift Classification per existing roof.

ORIGINATOR Mark D. Tyrol	DATE 10/18/00	REVIEWED BY	DATE
FOR ADMINISTRATIVE USE ONLY			
I-15 RECEIVED BY		DATE	
FOR AG OFFICE USE ONLY			
DATE RECEIVED _____ CHECKED IN PS _____ CHECKED IN ACCESS _____ CHAPTER & PAGE # _____			